



**KNIGHT FIRE & SECURITY PRODUCTS LTD**  
**Unit 84, Seawall Road Industrial Estate**  
**Tremorfa, Cardiff CF25 5TH**  
Tel: 029 2048 8129  
Fax: 029 2048 9132  
<mailto:info@knightfireandsecurity.com>

With Microswitch Tamper

CE

**Surface Magnetic Contact With Microswitch**



**Part Code: D25**

**Security Grade 2 Environmental Class 2**

**Manufactured to TS EN50131-2-6**



- ① Wire to the 2 terminals either side of the tact switch for the tamper.
- ② Wire to the 2 silver terminals to connect the alarm.

The operating gap is approx. 20mm.