





Safety Technology International

European Office
 Taylor House • 34 Sherwood Road • Bromsgrove
 Worcestershire • B60 3DR • England
 Tel: 44 (0) 1527 520 999 Fax: 44 (0) 1527 501 999
 E-mail: info@sti-emea.com • Web: www.sti-emea.com


USA - Headquarters
 2306 Airport Road • Waterford, Michigan 48327-1209
 Phone: 248-673-9898 • Fax: 248-673-1246
 E-mail: info@sti-usa.com • Web: www.sti-usa.com



PRODUCT DIMENSIONS



NOTE: MODELS REQUIRE KIT-71101B-*COLOUR* MODELS ONLY SUITABLE FOR EXTENDED DEPTH SURFACE MOUNTING DUE TO DIMENSIONS OF CONTACTS



*SS-2**4 and LT1 NOTES: For access control installations, power for the LT-1UL Timer must be supplied by a power source listed to UL294. When used for access control, this device shall be used as part of an access controlled egress door system. It is up to the local AHJ to allow use of this device in place of an automatic sensor. For higher security installations, lower time limits should be used. For SS-2** and LT1-UL the enclosed timer is to be used and installed per the enclosed LT-1UL installation sheet. SS-2**4 and LT1-UL maximum rating 30 VDC 3A.

WARNING: This product can expose you to chemicals including Dichloromethane, which is known to the State of California to cause cancer, and Bisphenol A (BPA) which is known to the State of California to cause birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov.

INSTALLATION OF SS2xx0, 2xx1, 2xx3 and 2xx4 SERIES STOPPER®STATION

All specifications and information shown were current as of publication, and are subject to change without notice






Safety Technology International

European Office
 Taylor House • 34 Sherwood Road • Bromsgrove
 Worcestershire • B60 3DR • England
 Tel: 44 (0) 1527 520 999 Fax: 44 (0) 1527 501 999
 E-mail: info@sti-emea.com • Web: www.sti-emea.com

USA - Headquarters
 2306 Airport Road • Waterford, Michigan 48327-1209
 Phone: 248-673-9898 • Fax: 248-673-1246
 E-mail: info@sti-usa.com • Web: www.sti-usa.com



INSTALLATION OF SS2xx0, 2xx1, 2xx3 and 2xx4 SERIES STOPPER® STATION

All specifications and information shown were current as of publication, and are subject to change without notice